



Punjab Alkalies & Chemicals Limited

Phone : 4072569 Grams: 'ALKALIES' Fax : 0172-2704797
 CIN:L24119CH1975PLC003607 Website : www.punjabalkalies.com
 Email : rakeshkaura@punjabalkalies.com,

Ref. No. PACL/SSR/2018/002/PL-RFQ

Dated 18.04.2018

Sub. : **Armoured Cables & Retrofitting of Breaker.**

Kindly send us your most competitive offers on/or before 28.04.2018 for the under mentioned Item :

S.No.	Description	UOM	Qty.
1.	3cx300 SQMM XLPE 11 KV HT CABLE	MTR.	245
<u>TECHNICAL SPECIFICATIONS</u>			
CIRCULAR STRANDED (RM/V) ARMOURED ALUMINIUM CONDUCTOR SHEILDING OF CONDUCTOR & CORE WITH EXTRUDED SEMI CONEDUCTING COMPOUND. XLPE INSULATED & SCREENED WITH COPPER TAPE. CONFIRMING TO IS 7098 (PART-I)/1988 WITH LATEST AMENDMENTS IF ANY. MAKE : ALCON/HAVELSS/RR CABEL/POLYCAB			
2.	Retrofitting of breaker	No.	1
<u>TECHNICAL SPECIFICATIONS</u>			
RETROFITTING OF 3-POLE, 11KV 1250AMP BREAKER WITH 2000 AMPERE BREAKER. SPECIFICATION OF EXISTING VCB IS AS: TYPE-3AF 1542-R, SR NO-5956, YEAR-1994, U-12KV, 50HZ, In-1250 AMPERE, I _{sc} -26.2 KA, I _{th} -3 SEC. U _w -75KV, M-100KG RATED OPERATING DUTY: O-3S-CO-3MIN-CO. MAKE: SIEMENS. WITH CURRENT TRANSFORMER 1600/1-1-1 AMP FOR EACH PHASE INCLUDING ERRECTION AND COMMISSIONING.			
3.	Retrofitting of 11KV MOC Breaker with 11KV VCB Siemen Make	No.	1
<u>TECHNICAL SPECIFICATIONS</u>			
1250AMPERE 11KV MOCB TO BE CONVERTED INTO 2000AMPERE 11KV VCB SPECIFICATION OF EXISITING MOCB: TYPE: 3AC-10N/1250-500/11EU, SR NO-1495, YEAR: 1982. Un-12KV, 50HZ, In-1250/AMPERE. In-1250AMPERE, Na-500MVA Imake-75/65KV, I _{thermal} -30KA(I SEC), RATED OPERATED DUTY: O-T-CO-T-CO MAKE: SIEMENS WITH CURRENT TRANSFORMER 1600/1-1-1 AMPERE FOR EACH PHASE INCLUDING ERRECTION AND COMMISSIONING.			

Terms & Conditions :

For PUNJAB ALKALIES & CHEMICALS LTD.

Please send your quotation in a sealed envelope mentioning our enquiry Ref. No. strictly on the top of the envelope.

RAKESH KUMAR KAURA
 Manager (Purchase)

tender_ Uploading (3)

| Page



Punjab Alkalies & Chemicals Limited

Phone : 4072569 Grams: 'ALKALIES' Fax : 0172-2704797
CIN;L24119CH1975PLC003607Website : www.punjabalkalies.com
Email :rakeshkaura@punjabalkalies.com,

1. Quotation received after the due date may not be considered.
2. Exact rates of GST etc. whenever livable should be clearly specified by you in your quotation, as no subsequent claims will be entertained by us in respect of these, it will not be sufficient to applicable.
3. Any alteration or erasure in the quotation should be absolutely legible & duly attested. Over-writing or over-typing of any information may disqualify your quotation.
4. Our enquiry reference must be indicated clearly on top of the envelope.
5. Your quotation must be for units specified in this enquiry and should be valid for 90- days from date of opening of offer.
6. At our option we may change the quantity of our requirement, or delete items.
7. Please give detailed specification and indicate the name of manufacturer of each item and enclose literature.
8. Your offer should be duly supported by all relevant technical literature/catalogue/brochure etc.
9. Please quote clearly whether your warehouse is covered under excise preview or not. We shall like you to supply material through covetable invoice. Next of modvat notes will be compared fro commercial evaluation.