



Punjab Alkalies & Chemicals Limited

Regd. Office : S.C.O. 125-127, Sector 17-B, Chandigarh - 160 017 (INDIA)
 Phone : 0172-4072508-568, E- mail : info@punjabalkalies.com Fax : 0172-2704797
 CIN : L24119CH1975PLC003607, Website : www.punjabalkalies.com



RFQ Master Enquiry

Ref No PACL/ENQ/1/kkg/PL-RFQ-00650

Date 06/10
 Unit ALL

Dear Sir,

Kindly Send us your most competitive offers so as to reach us on or before 22-OCT-18 for the supply of the under mentioned items :

S. Item Code / No Description Of Material	Quantity Unit	
1 PL-039-29917 BUTTERFLY CONTROL VALVE 3"	1.000 NO	<p>BUTTERFLY CONTROL VALVE WITH ACTUATOR, VALVE SIZE-80 MM, FLUID-BRINE, ABS. INLET PRESSURE= 5.0BAR(A), DELTA PV, PRESSURE DROP- 0/MIN., OP.TEMPERATURE-70DEG C, LIQUID DENSITY- 1180KG/M3, SHUTOFF PRESSURE-8.0 BAR(A), POSITION ON AIR FAILURE-CLOSE, BODY TYPE-BUTTERFLY WAFER DESIGN, PRESSURE RATING-ANSI 150#, END CONNECTIONS=SANDWICHED BETWEEN ANSI B16.5 FLANGES, BODY MATERIAL=EPOXY COATED DUCTILE IRON PTFE LINED(3 MM THK MIN), FACE TO FACE- 46 MM. BONNET:-STANDARD, GLAND PACKING- STUFFING BOX TYPE PTFE.TRIM CHARACTERISTICS- CONTROL, SEALING SEAT/PLUG- PFA/PTFE, LEAKAGE CLASS- ANSI B16.104 CLASS VI, DISC MATERIAL-DI PFA LINED, SHAFT-DI PFA LINED, OPERATION=PNEUMATIC OPERATED BY ACTUATOR, ACTUATOR= RACK AND PINION TYPE SINGLE ACTING HAVING PNEU OP PRESSURE- 3.5 / 4.0 BAR(G) (NORMAL) WITH AIR TO OPEN ACTION, HARD ANODIZED EXTRUDED AL BODY WITH MULTI SPRINGS SUITABLE FOR FINE-TUNING OF ACTUATOR WITH VARYING PLANT AIR PRESSURE, SPRING STEEL ELECTROSTATIC RESIN COATED SPRINGS,</p>

FOLLOWING ACCESSORIES SHOULD BE DULY MOUNTED ON THE VALVE.

1. YTC/POWER GENEX MAKE WEATHER PROOF ELECTROPNEUMATIC POSITIONER WITH 4 TO 20 MA INPUT, PRESSURE GAUGES, 1/4" NPT(F) PNEUMATIC CONNECTIONS, ELECTRICAL ENTRY WITH DC

RFQ Master Enquiry

CABLE
GLANDS, MOUNTING BRACKET & LINK

2. 3/2 WAY, 110 VAC, 50 HZ SOLENOID VALVE, ENCLOSURE WEATHERPROOF, BODY: SS316, WETTED
PARTS: SS316, TERMINAL BOX TYPE COIL AND DOUBLE COMPRESSION CABLE GLANDS FOR ELECTRICAL CONNECTIONS, PR CONNECTION: 1/4 INCH NPT(F)
3. AIR FILTER REGULATOR (0 TO 7) KG/CM² (SHAVO/PLACKA) WITH OUTLET PRESSURE GAUGE and AIR CONNECTION 1/4 INCH NPT(F), BODY: DIECAST AL EPOXY PAINTED, SPINDLE/DRAIN PLUG: SS304, FILTER: SINTERED BRONZE

NOTE :

ACTUATOR SHOULD BE DULY MOUNTED ON THE VALVE AND TRANSMISSION COUPLING DIRECTLY MOUNTED ON THE ACTUATOR HELD BY CORROSION RESISTANT MOUNTING BRACKET - MOUNTING AS PER ISO STDS. OTHER ACCESORIES SHOULD ALSO BE DULY MOUNTED AND TUBED WITH THE ACTUATOR WHERE REQUIRED (SS ANNEALED TUBE IN 8 MM OD) ALL COMPRESSION FITTINGS AND CONNECTORS SHOULD BE IN SS 316.

2 PL-039-31235 1.000 NO BARE STEM BUTTERFLY VALVE, MAKE =
 BUTTERFLY VALVE BODY 80MM RICHTER, SIZE = 80
 MM, MODEL = NKS/F WITH ISO 5211
 MOUNTING TO REPLACE
 EXISTING FAULTY 'RICHTER' BUTTERFLY
 VALVE WITH
 EXISTING ROTARY ACTUATOR,
 FLUID-BRINE, ABS. INLET PRESSURE-
 5.0BAR(A), DELTA PV, PRESSURE DROP-
 0/MIN.,
 OP. TEMPERATURE-70DEG C, LIQUID
 DENSITY=1180KG/M3,
 SHUTOFF PRESSURE-8.0 BAR(A), BODY TYPE-
 BUTTERFLY
 WAFER DESIGN, PRESSURE RATING-ANSI
 150#,
 END CONNECTIONS=SANDWICHED BETWEEN
 ANSI B16.5

RFQ Master Enquiry

FLANGES, BODY MATERIAL=EPOXY COATED
 DUCTILE IRON
 PTFE LINED(3 MM THK MIN),
 BONNET:-STANDARD, GLAND PACKING-
 STUFFING BOX TYPE
 PTFE, SEALING SEAT/PLUG- PFA/PTFE,
 LEAKAGE CLASSANSI
 B16.104 CLASS VI, DISC MATERIAL-DI PFA
 LINED, SHAFT-DI PFA LINED.

Terms & Conditions :

Note: Please send your offer in two separate envelopes having priced & technical bid before due date. Material is required at Nangal (punjab). Please Quote CST, VAT

Please send your quotation in a sealed envelop mentioning our enquiry Ref.No. strictly on the top of the envelope.

For PUNJAB ALKALIES & CHEMICAL LIMITED

KRISHAN KUMAR GOYAL

DEPUTY MANAGER(PURCHASE)

-
- 1.Quotation received after the due date may not be considered.
 - 2.Exact rates of Sales Tax, Central Sales Tax, Excise duty,Octroi etc. whenever leviable should be clearly specified by you in your quotation, as no subsequent claims will be entertained by us in respect of these, it will not be sufficient to applicable.
 - 3.Any alteration or erasure in the quotation should be absolutely legible & duly attested. Over-writing or over-typing of any information may disqualify your quotation.
 - 4.Our enquiry reference must be indicated clearly on top of the envelope.
 - 5.Your quotation must be for units specified in this enquiry and should be valid for 90 days from date of opening of offer.
 - 6.At our option we may change the quantity of our requirment, or delete items.
 - 7.Please give detailed specification and indicate the name of manufacturer of each item and enclose literature.
 - 8.Your offer should be duly supported by all relevent technical literature/catalogue/brochure etc.
 - 9.Please quote clearly whether your warehouse is covered under excise preview or not. We shall like you to supply material through cenvetable invoice. Next of modvat notes will be compared for commercial evaluation.

IMP: PLEASE INDICATE TARRIF/SUB HEAD UNDER WHICH EXCISE DUTY IS TO BE CHARGED.