

**paci****Punjab Alkalies & Chemicals Limited**

Regd. Office : S.C.O. 125-127, Sector 17-B, Chandigarh - 160 017 (INDIA)

Phone : 0172-4072000-500, E-mail : [info@punjabalkalies.com](mailto:info@punjabalkalies.com) Fax : 0172-2704797CIN : L24119CH1975PLC003807, Website : [www.punjabalkalies.com](http://www.punjabalkalies.com)

Ref No PACL/ENQ/1/kkg/PL-RFQ-01041

Date 14/03/20

Unit ALL



Dear Sir,

Kindly Send us your most competitive offers so as to reach us on or before 27-MAR-18 for the supply of the under mentioned items :

S. Item Code / Quantity Unit  
No Description Of Material

S. Item Code / No	Quantity Unit	Description Of Material
1 PL-039-28663 BUTTERFLY ON/OFF CONTROL VALVE 150MM	3.000 NO	<p>BUTTERFLY ON/OFF VALVE WITH ROTARY ACTUATOR, VALVE SIZE-150 MM., FLUID-BRINE, ABS. INLET PRESSURE-5.0BAR (A), DELTA PV, PRESSURE DROP-0/MIN., OP. TEMPERATURE-70DEG C, LIQUID DENSITY-1180KG/M3, SHUTOFF PRESSURE-8.0 BAR (A), POSITION ON AIR FAILURE-CLOSE, BODY TYPE-BUTTERFLY WAFER DESIGN, PRESSURE RATING-ANSI 150#, END CONNECTIONS=SANDWICHED BETWEEN ANSI B16.5 FLANGES, BODY MATERIAL=EPOXY COATED DUCTILE IRON PTFE LINED (3 MM THK MIN), FACE TO FACE-56 MM. BONNET:- STANDARD, GLAND PACKING-STUFFING BOX TYPE PTFE. TRIM CHARACTERISTICS- ON/OFF, SEALING SEAT/PLUG- PFA/PTFE, LEAKAGE CLASS-ANSI B16.104 CLASS VI, DISC MATERIAL-DI PFA LINED, SHAFT-DI PFA LINED, OPERATION=PNEUMATIC OPERATED BY ACTUATOR, ACTUATOR= RACK AND PINION TYPE SINGLE ACTING HAVING PNEU OP PRESSURE- 3.5 / 4.0 BAR (G) (NORMAL) WITH AIR TO OPEN ACTION, HARD ANODIZED EXTRUDED AL BODY WITH MULTI SPRINGS SUITABLE FOR FINE-TUNING OF ACTUATOR WITH VARYING PLANT AIR PRESSURE, SPRING STEEL ELECTROSTATIC RESIN COATED SPRINGS, ACCESSORIES:-</p> <p>1. 3/2 WAY, 110 VAC, 50 HZ SOLENOID VALVE, ENCLOSURE WEATHERPROOF, BODY: SS316, WETTED PARTS: SS316, TERMINAL BOX TYPE COIL AND DOUBLE COMPRESSION CABLE GLANDS FRO ELECTRICAL CONNECTIONS, PR CONNECTION: 1/4 INCH NPT (F)</p> <p>2. AIR FILTER REGULATOR (0 TO 7) KG/CM2 (SHAVO/PLACKA) WITH OUTLET PRESSURE GAUGE and AIR CONNECTION 1/4 INCH NPT (F), BODY: DIECAST AL EPOXY PAINTED, SPINDLE/DRAIN PLUG: SS304, FILTER: SINTERED BRONZE</p> <p>3. ACTUATOR MOUNTED VISUAL INDICATION FOR VALVE OPEN/CLOSE STATUS.</p> <p>NOTE : ACTUATOR SHOULD BE DULY MOUNTED ON THE VALVE AND TRANSMISSION COUPLING</p>



DIRECTLY MOUNTED ON THE ACTUATOR HELD

## RFQ Master Enquiry

BY CORROSION RESISTANT MOUNTING  
 BRACKET - MOUNTING AS PER ISO STDS.  
 OTHER ACCESORIES SHOULD ALSO BE DULY  
 MOUNTED AND TUBED WITH THE ACTUATOR  
 WHERE REQUIRED (SS ANNEALED TUBE IN 8  
 MM OD)  
 ALL FITTINGS AND CONNECTORS SHOULD BE  
 IN SS 316.

ACCEPTABLE MAKES:  
 RICHTER/PFEIFFER/DURCO/TYCO

---

 Terms & Conditions :

Note: Please send your offer in two seperate envelopes having priced & technical bid before due date. Material is required at Nangal (punjab). Please Quote CST,VAT

Please send your quotation in a sealed envelop mentioning our enquiry Ref.No. strictly on the top of the envelope.

For PUNJAB ALKALIES & CHEMICAL LIMITED

  
 KRISHAN KUMAR GOYAL  
 Deputy Manager (Purchase)

- 
1. Quotation received after the due date may not be considered.
  2. Exact rates of Sales Tax, Central Sales Tax, Excise duty, Octroi etc. whenever leviable should be clearly specified by you in your quotation, as no subsequent claims will be entertained by us in respect of these, it will not be sufficient to applicable.
  3. Any alteration or erasure in the quotation should be absolutely legible & duly attested. Over-writing or over-typing of any information may disqualify your quotation.
  4. Our enquiry reference must be indicated clearly on top of the envelope.
  5. Your quotation must be for units specified in this enquiry and should be valid for 90 days from date of opening of offer.
  6. At our option we may change the quantity of our requirment, or delete items.
  7. Please give detailed specification and indicate the name of manufacturer of each item and enclose literature.
  8. Your offer should be duly supported by all relevent technical literature/catalogue/brochure etc.
  9. Please quote clearly whether your warehouse is covered under excise preview or not. We shall like you to supply material through cenvetable invoice. Next of modvat notes will be compared for commercial evaluation.

IMP: PLEASE INDICATE TARRIF/SUB HEAD UNDER WHICH EXCISE DUTY IS TO BE CHARGED.