



Punjab Alkalies & Chemicals Limited

Regd. Office : S.C.O. 125-127, Sector 17-B, Chandigarh - 160 017 (INDIA)

Phone : 0172-4072608-867, E-mail : info@punjabalkalies.com Fax : 0172-2704797

CIN : L24119CH1975PLC003607, Website : www.punjabalkalies.com

Ref No PACL/ENQ/1/kkg/PL-RFQ-00252.

Date 22/06/2017

Unit ALL



Dear Sir,

Kindly Send us your most competitive offers so as to reach us on or before 04-JUL-17 for the supply of the under mentioned items :

S. Item Code / No Description Of Material	Quantity Unit	
1 PL-039-61055 MAG FLOWMETER 50MM WITH TANTALUM ELECTRODES.	1.000 NO	Fluid: Acidified Brine, Operating pressure (normal)= 2 bar(A), Size 50mm, Fluid temp.= 90 deg C, Density 1120 kg/m3, Dynamic viscosity 0.5 m Pas, Flow Range =0 to 25 M3/hr, Calibrated range 20 m3/hr, process connections = Flanged, Flange size= 2" as per ANSI #150RF of SS316 with PTFE/PFA lining on raised portion, Face to face dimension =200mm, Flow tube body MOC SS316 with PTFE lining, Process Flange in SS316, Coil housing in SS, Trans. housing =Die cast Alum. with anti corrosive coating, protection class= IP67, Electrode material= Tantalum, Earthing plate rings material =Tantlum thickness 2mm(Max.), transmitter aux. power supply =85 to 240 VAC, 50 Hz, Output= 4 to 20 mA DC, HART, Electrical connections= 1/2"nptf with DC cable glands in SS, local LCD display with keypad UI for all Programing & Maintenance features. Acceptable make = Yokogawa, Emerson

Terms & Conditions :

Note: Please send your offer in two seperate envelopes having priced & technical bid before due date. Material is required at Nangal (punjab). Please Quote CST,VAT

For PUNJAB ALKALIES & CHEMICAL LIMITED

Please send your quotation in a sealed envelop mentioning our enquiry Ref.No. strictly on the top of the envelope.

KRISHAN KUMAR GOYAL
Deputy Manager (Purchase)

1. Quotation received after the due date may not be considered.
2. Exact rates of Sales Tax, Central Sales Tax, Excise duty, Octroi etc. whenever leviable should be clearly specified by you in your quotation, as no subsequent claims will be entertained by us in respect of these, it will not be sufficient to applicable.
3. Any alteration or erasure in the quotation should be absolutely legible & duly attested. Over-writing or over-typing of any information may disqualify your quotation.

4. Our enquiry reference must be indicated clearly on top of the envelope.

RFQ Master Enquiry

5. Your quotation must be for units specified in this enquiry and should be valid for 90 days from date of opening of offer.
6. At our option we may change the quantity of our requirement, or delete items.
7. Please give detailed specification and indicate the name of manufacturer of each item and enclose literature.
8. Your offer should be duly supported by all relevant technical literature/catalogue/brochure etc.
9. Please quote clearly whether your warehouse is covered under excise preview or not. We shall like you to supply material through cenvetable invoice. Next of modvat notes will be compared for commercial evaluation.

IMP: PLEASE INDICATE TARRIF/SUB HEAD UNDER WHICH EXCISE DUTY IS TO BE CHARGED.