



Punjab Alkalies & Chemicals Limited

Regd. Office : S.C.O. 125-127, Sector 17-B, Chandigarh - 160 017 (INDIA)

Phone : 0172-4072508-567, E-mail : info@punjabalkalies.com Fax : 0172-2704797

CIN : L24119CH1975PLC003607, Website : www.punjabalkalies.com

Ref No PACL/ENQ/1/kkg/PL-RFQ-00308

Date 06/07/2017

Unit ALL



Dear Sir,

Kindly Send us your most competitive offers so as to reach us on or before 20-JUL-17 for the supply of the under mentioned items :

S. No	Item Code / Description Of Material	Quantity	Unit	
1	PL-039-10520 LEVEL TRANSMITTER FOR CL2 STORAGE TANK.	1.000	NO	Service=Liquid chlorine, Type=Radar type, Application=Level measurement of chlorine storage tanks, Operating Temp.=(-)5DegC (N), (+)40DegC (Max.), (-)15DegC (Min) Pressure=1bar (min.), 15 bar (max.), Fluid Density=1500 Kg/m3, Fluid Viscosity=0.42cp, Accuracy=(+/-)2mm or better, Process connections=2"ANSI 300# RF, Probe type=Coaxial or suitable, Probe length=3350mm, Probe MOC/Wetted parts=Hastelloy-C, Gasket/scaling=suitable for pressurized liquid chlorine, Aux. power=12 to 32 VDC, 2 Wire, Output =4 to 20 mA, HART, Output should not hold on error, Digital LCD display with UI interactive push buttons for all programming and diagnostic features, should be able to display local reading in percentage as well as mm, Electrical connections=1/2"NPT(F) with DC Cable glands in Ni. plated brass/SS, Transmitter housing=Die cast Al. with anticorrosive coating, Protection class=IP67, Calibration & material traceability certificate.

Terms & Conditions :

Note: Please send your offer in two separate envelopes having priced & technical bid before due date. Material is required at Nangal (punjab). Please Quote CST, VAT

Please send your quotation in a sealed envelop mentioning our enquiry Ref.No. strictly on the top of the envelope.

For PUNJAB ALKALIES & CHEMICAL LIMITED

KRISHAN KUMAR GOYAL
Deputy Manager (Purchase)

1. Quotation received after the due date may not be considered.
2. Exact rates of Sales Tax, Central Sales Tax, Excise duty, Octroi etc. whenever

leviable should be clearly specified by you in your quotation, as no subsequent

RFQ Master Enquiry

claims will be entertained by us in respect of these, it will not be sufficient to applicable.

3. Any alteration or erasure in the quotation should be absolutely legible & duly attested. Over-writing or over-typing of any information may disqualify your quotation.
4. Our enquiry reference must be indicated clearly on top of the envelope.
5. Your quotation must be for units specified in this enquiry and should be valid for 90 days from date of opening of offer.
6. At our option we may change the quantity of our requirement, or delete items.
7. Please give detailed specification and indicate the name of manufacturer of each item and enclose literature.
8. Your offer should be duly supported by all relevant technical literature/catalogue/brochure etc.
9. Please quote clearly whether your warehouse is covered under excise preview or not. We shall like you to supply material through cenvetable invoice. Next of modvat notes will be compared for commercial evaluation.

IMP: PLEASE INDICATE TARRIF/SUB HEAD UNDER WHICH EXCISE DUTY IS TO BE CHARGED.