



# Punjab Alkalies & Chemicals Limited

Regd. Office : S.C.O. 125-127, Sector 17-B, Chandigarh - 160 017 (INDIA)

Phone : 0172-4072500-507 E-mail : [Info@punjabalkalies.com](mailto:Info@punjabalkalies.com) Fax : 0172-2704797

CIN : L24119CH1975PLC003607, Website : [www.punjabalkalies.com](http://www.punjabalkalies.com)

Ref No PACL/ENQ/1/kkg/PL-RFQ-00468

Date 14/09/2017

Unit ALL



Dear Sir,

Kindly Send us your most competitive offers so as to reach us on or before 28-SEP-17 for the supply of the under mentioned items :

S. No	Item Code / No Description Of Material	Quantity	Unit
1	PL-039-14327 <u>DIFFERENTIAL PRESSURE TRANSMITTER FOR</u> <u>MOIST.CL2</u>	1.000	NO
			DIFFRENTIAL PRESSURE TRANSMITTER, TAG:PDT1159 TYPE REMOTE SEAL, SERVICE: (+VE SIDE)= H2 GAS, (-VE SIDE): MOIST CL2 GAS MAX OPERATING TEMP ON BOTH SIDES: 95 DEG C OPERATING PRESSURE:(+VE SIDE)= 0/0.215/0.4 BAR(G) (-VE SIDE)=0/0.2/0.4 BAR(G) CALIBERATED SPAN REQUIRED: (0-50) mBAR AND SHOULD BE ADJUSTABLE OVER ENTIRE RANGE OF TRANSMITTER MEASURING ELEMENT: DIAPHRAGM(+/-) REMOTE SENSING DIAPHRAGM MOCAND WETTED PARTS: (+VE)= HAST-C, (-VE)= TANTALUM, FILL FLUID ON BOTH SIDES: INERT OIL, CAPPILARY LENGTH: 1.5 MTRS ON BOTH SIDES, CAPPILARY MOC: SS316 ARMOURED STATIC PRESSURE LIMIT: 4.0 BAR(A) (MIN), 18.9 BAR(A) (MAX), I/P SUPPLY: 10.2 TO 32VDC, 2 WIRE O/P 4 TO 20mA, HART, DISPLAY: LOCAL LCD DISPLAY WITH USER INTERFACE SWITCHES FOR ZERO, RANGE SETTINGS AND OTHER PROGRAMMING FEATURES, ACCURACY: +/- 0.25% OF SPAN, RANGABILITY: 100:1 PROCESS CONNECTION FOR BOTH SIDES: REMOTE SEAL WITH 3" NB BACK UP FLANGE FLANGE RATING/FACING: ANSI 150#/RF/ANSI B16.5, FLANGE MOC: SS316 CABLE ENTRY: 1/2" NPT(F) WITH DC CABLE GLANDS, TRANSMITTER HOUSING: DIE CAST ALUMINIUM WITH ANTICORROSIVE COATING NOTE1: BOTH REMOTE SEALS TO BE MOUNTED ON SAME HORIZONTAL PLANE NOTE2: TRANSMITTER SHOULD BE SUPPLIED WITH SS 316 MOUNTING ACCESSORIES SUITABLE FOR MOUNTING ON 2" PIPE MOUNTING NOTE3: MAINTENANCE/ OPERATING MANUAL TO BE PROVIDED IN HARD/SOFT COPY ACCEPTABLE MAKES = YOKOGAWA OR EMERSON.


Terms & Conditions :

RFQ Master Enquiry

Note: Please send your offer in two separate envelopes having priced & technical bid before due date. Material is required at Nangal (punjab). Please Quote CST,VAT

For PUNJAB ALKALIES & CHEMICAL LIMITED

Please send your quotation in a sealed envelop mentioning our enquiry Ref.No. strictly on the top of the envelope.

  
KRISHAN KUMAR GOYAL  
Deputy Manager (Purchase)

- 
1. Quotation received after the due date may not be considered.
  2. Exact rates of Sales Tax, Central Sales Tax, Excise duty, Octroi etc. whenever leviable should be clearly specified by you in your quotation, as no subsequent claims will be entertained by us in respect of these, it will not be sufficient to applicable.
  3. Any alteration or erasure in the quotation should be absolutely legible & duly attested. Over-writing or over-typing of any information may disqualify your quotation.
  4. Our enquiry reference must be indicated clearly on top of the envelope.
  5. Your quotation must be for units specified in this enquiry and should be valid for 90 days from date of opening of offer.
  6. At our option we may change the quantity of our requirement, or delete items.
  7. Please give detailed specification and indicate the name of manufacturer of each item and enclose literature.
  8. Your offer should be duly supported by all relevant technical literature/catalogue/brochure etc.
  9. Please quote clearly whether your warehouse is covered under excise preview or not. We shall like you to supply material through cenvetable invoice. Next of modvat notes will be compared for commercial evaluation.

IMP: PLEASE INDICATE TARRIF/SUB HEAD UNDER WHICH EXCISE DUTY IS TO BE CHARGED.