



Punjab Alkalies & Chemicals Limited

Regd. Office : S.C.O. 125-127, Sector 17-B, Chandigarh - 160 017 (INDIA)
 Phone : 0172-4072508-587, E-mail : info@punjabalkalies.com Fax : 0172-2704797
 CIN : L24119CH1975PLC003607, Website : www.punjabalkalies.com



Ref No PACL/ENQ/1/kkg/PL-RFQ-00651

Date 17/11/2017
 Unit ALL

Dear Sir,

Kindly Send us your most competitive offers so as to reach us on or before 02-DEC-17 for the supply of the under mentioned items :


S. No	Item Code / Description Of Material	Quantity	Unit	
1	PL-039-00296 ALPHALINE FLANGE LIQUID LEVEL TRANSMITTER 45A0F22	2.000	NO	Service: Lean Brine/Acidified Brine/30% HCL, O.P Pressure Atmospheric, O.P Temp. 95 deg. C, Measuring element diaphragm, process connection(+) 3" NB flush flanged, Flange MOC SS316/316L, Flange rating/Facing= ANSI B16.5/RF/150#, Flange finish:63-125, Static pressure limits=0.4BAR(A) Min. 18.9(A) Max.Process connection (LP) 1/2" NPT(F) with adaptor, Diaphragm MOC: Tantalum, Fill fluid=Inert oil, Other Wetted Parts: Tantalum,Gasket O rings : PTFE, Power supply (9-24)VDC, 2 wire, reverse polarity protection, O/P 4 to 20MA, HART, Cable Entry 1/2"(F) with DC cable glands in PVC, Accuracy(+/-) 0.075% of span, Display :digital LCD with LOI suitable for all programming features including zero, span, damping, calibration etc., display should indicate level in 0 to 100% locally, Protection class IP 67, Transmitter housing die cast Al with Anti corrosive paint/Coat, Transmitter range 0-12000mmwc, Turn down ratio 100:1, Acceptable makes : Yokogawa/Emerson/Fuji

Terms & Conditions :

Note: Please send your offer in two separate envelopes having priced & technical bid before due date. Material is required at Nangal (punjab). Please Quote CST,VAT

Please send your quotation in a sealed envelop mentioning our enquiry Ref.No. strictly on the top of the envelope.

For PUNJAB ALKALIES & CHEMICAL LIMITED


 KRISHAN KUMAR GOYAL
 Deputy Manager (Purchase)

1. Quotation received after the due date may not be considered.
2. Exact rates of Sales Tax, Central Sales Tax, Excise duty, Octroi etc. whenever leviable should be clearly specified by you in your quotation, as no subsequent claims will be entertained by us in respect of these, it will not be sufficient

to applicable.

RFQ Master Enquiry

3. Any alteration or erasure in the quotation should be absolutely legible & duly attested. Over-writing or over-typing of any information may disqualify your quotation.
4. Our enquiry reference must be indicated clearly on top of the envelope.
5. Your quotation must be for units specified in this enquiry and should be valid for 90 days from date of opening of offer.
6. At our option we may change the quantity of our requirement, or delete items.
7. Please give detailed specification and indicate the name of manufacturer of each item and enclose literature.
8. Your offer should be duly supported by all relevant technical literature/catalogue/brochure etc.
9. Please quote clearly whether your warehouse is covered under excise preview or not. We shall like you to supply material through cenvetable invoice. Next of modvat notes will be compared for commercial evaluation.

IMP: PLEASE INDICATE TARRIF/SUB HEAD UNDER WHICH EXCISE DUTY IS TO BE CHARGED.