



Punjab Alkalies & Chemicals Limited

Regd. Office : S.C.O. 125-127, Sector 17-B, Chandigarh - 160 017 (INDIA)

Phone : 0172-4072808-807, E-mail : info@punjabalkalies.com Fax : 0172-2704797

CIN : L24119CH1975PLC003607, Website : www.punjabalkalies.com

Ref No PACL/ENQ/1/kgg/PL-RFQ-00938

Date 21/02/2011

Unit ALL



Dear Sir,

Kindly Send us your most competitive offers so as to reach us on or before 07-MAR-18 for the supply of the under mentioned items :

S. Item Code / No Description Of Material	Quantity Unit	
1 PL-039-09997 CL2 MONITOR WITH ALARM MODULE	4.000 SET	<p>CL2 monitoring system with local hooter and audio visual alarms for measuring CL2 gas in atmosphere...consisting of :-</p> <p>(a) Indicator for instantaneous reading of CL2 gas, LED display, UI push buttons for programming, calibration, range setting, Alarm setting etc. features, Aux. Power supply=230 VAC, 50 Hz, (+/-)10%, three nos. Potential free contacts with internal relays and switch rating of 250 VAC @ 5 amp for local hooter and visual alarms, alarm set points should be adjustable over entire range, measuring Range=0 to 20 PPM or 0 to 10 PPM, Resolution = 0.1PPM, industrial hooter and panel/wall mounting accessories for field mounting of indicator and hooter mounting to be supplied by vendor.</p> <p>(b) Electrochemical plug n play, hot awappable type, Expected service life of sensor = 36 months, Zero shift=less than 2% of full scale/month, Span drift=less than 3% per month, . Environmental conditions=Temperature (min/max.) (-)10 (+)50 Deg C, Humidity=10/95%,</p> <p>(a) Combined accuracy & sensor response time=Vendor to specify. (b) Test & calibration certificates of Authorized agency should be supplied.</p>

Terms & Conditions :

Note: Please send your offer in two separate envelopes having priced & technical bid before due date. Material is required at Nangal (punjab). Please Quote CST,VAT

RFQ Master Enquiry

For PUNJAB ALKALIES & CHEMICAL LIMITED

Please send your quotation in a sealed envelop mentioning our enquiry Ref.No. strictly on the top of the envelope.

KRISHAN KUMAR GOYAL
Deputy Manager(Purchase)

-
- 1.Quotation received after the due date may not be considered.
 - 2.Exact rates of Sales Tax, Central Sales Tax, Excise duty,Octroi etc. whenever leviabale should be clearly specified by you in your quotation, as no subsequent claims will be entertained by us in respect of these, it will not be sufficient to applicable.
 - 3.Any alteration or erasure in the quotation should be absolutely legible & duly attested. Over-writing or over-typing of any information may disqualify your quotation.
 - 4.Our enquiry reference must be indicated clearly on top of the envelope.
 - 5.Your quotation must be for units specified in this enquiry and should be valid for 90 days from date of opening of offer.
 - 6.At our option we may change the quantity of our requirment, or delete items.
 - 7.Please give detailed specification and indicate the name of manufacturer of each item and enclose literature.
 - 8.Your offer should be duly supported by all relevent technical literature/catalogue/brochure etc.
 - 9.Please quote clearly whether your warehouse is covered under excise preview or not. We shall like you to supply material through cenvetable invoice. Next of modvat notes will be compared for commercial evaluation.

IMP: PLEASE INDICATE TARRIF/SUB HEAD UNDER WHICH EXCISE DUTY IS TO BE CHARGED.